

ICC-ES PMG Product Certificate

PMG-1508



Effective Date: September 2019 This listing is subject to re-examination in one year.

www.icc-es-pmg.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 22 00 00—PLUMBING

> 22 13 53—Facility Septic Tanks Section:

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Product: Hishitank™

Listee: Mitsubishi Chemical Infratec

1-2-2 Nihonbashihongoku-cho, Chuo-ku

Tokyo, 103-0021

Japan

www.mp-infratec.co.jp

Compliance with the following codes:

2018, 2015, 2012, 2009 and 2006 International Residential Code® (IRC) 2018, 2015, 2012, 2009 and 2006 International Plumbing Code® (IPC) 2018, 2015, 2012, 2009 and 2006 Uniform Plumbing Code* (UPC)* 2019, 2016, 2013 and 2010 California Plumbing Code (CPC) 2017 City of Los Angeles Plumbing Code

*Copyrighted publications of the International Association of Plumbing and Mechanical Officials.

Compliance with the following standards:

AWWA D121-12, Bolted Aboveground Thermosetting Fiberglass-Reinforced Plastic Panel-Type Tanks for Water Storage

IAPMO PS 52-2019 Pump/Dose, Sumps and Sewage Ejector Tanks With or Without a Pump IAMPO/ANSI Z1002-2014 Rain Harvesting Tanks

Identification:

Each tank shall be permanently marked with the following:

- Manufacture's name or trademark.
- Model Number or serial number
- Working liquid volume
- Date, date code or identifier traceable to the date of manufacturer
- **ICC-ES PMG Listing Mark**



Installation:

The HishitankTM must be installed in accordance with the manufacturer's published installation instructions and the applicable code. The HishitankTM is recognized for indoor and above ground installation.

Models:

Hishitank™ G Panel type is a modular water tank consists of fiberglass reinforced polymer panels and steel bars.

Hishitank[™] G Panel type has been evaluated to comply with IAPMO/ANSO Z1002 and IAPMO PS52 for storm water, grey water and black water storage applications.

Conditions of listing:

- 1. The Hishitank™ G Panel type recognized in this listing must be installed in accordance with the manufacturer's published installation instructions and the applicable code.
- 2. The Hishitank[™] G Panel type is recognized for indoor installation above ground only.
- 3. The Hishitank™ G Panel type is recognized for above ground installation only.
- 4. The storage of drinking water is outside scope of this listing.
- 5. Seismic evaluation is outside scope of this listing.
- 6. The Hishitank™ G Panel type is manufactured under a quality control program with an annual surveillance inspection by ICC-ES.